

위치	측 정 치					평균치	평균치	타격각도	▽R1	▽R3	기준강도	f	재령	α	f ₂₈	Mpa	추정강도
						(R ₁)	(R ₂)	(α)	(ΔR)	(ΔR')	(R ⁰)						
A1 흉벽	55	53	52	52	49	49.5	49.5	0	0.00	0	49.5	44.9	2000	0.64	28.7	24	29.1
	52	50	46	48	47												
	51	47	50	51	46										29.5		
	48	49	48	48	48							46.1					
P1 기둥	55	50	46	53	51	52.4	52.4	0	0.00	0	52.4	48.5	2000	0.64	31.1	27	31.0
	54	52	52	51	53												
	52	52	52	54	54										30.9		
	52	54	54	52	55							48.3					
P2 기둥	50	48	46	51	51	50.9	50.9	0	0.00	0	50.9	46.6	2000	0.64	29.9	27	30.0
	53	51	48	49	50												
	55	51	51	50	49										30.2		
	52	52	53	55	53							47.2					
P3 기둥	49	51	51	50	53	51.8	51.8	0	0.00	0	51.8	47.8	2000	0.64	30.6	27	30.6
	54	52	50	50	52												
	55	51	55	52	50										30.6		
	51	54	54	54	48							47.8					
P4 기둥	48	50	45	51	53	50.0	50.0	0	0.00	0	50.0	45.5	2000	0.64	29.1	27	29.4
	49	48	48	50	50												
	51	50	51	52	53										29.8		
	47	48	50	51	55							46.5					
P5 기둥	47	47	48	50	50	49.8	49.8	0	0.00	0	49.8	45.2	2000	0.64	29.0	27	29.3
	49	48	50	50	53												
	53	51	51	50	48										29.7		
	54	51	50	47	48							46.4					
P6 기둥	55	50	55	54	51	51.4	51.4	0	0.00	0	51.4	47.3	2000	0.64	30.3	27	30.3
	51	52	47	47	50												
	49	48	53	52	52										30.4		
	52	52	55	52	51							47.5					
P7 코핑부배면	50	56	56	51	52	50.1	50.1	0	0.00	0	50.1	45.6	2000	0.64	29.2	27	29.5
	51	49	48	47	48												
	51	48	50	48	48										29.8		
	49	52	48	48	51							46.6					
P8 기둥	51	52	51	48	47	50.1	50.1	0	0.00	0	50.1	45.6	2000	0.64	29.2	27	29.5
	54	49	48	47	50												
	52	51	51	50	50										29.8		
	50	50	48	49	53							46.6					
P9 기둥	50	55	48	51	53	51.3	51.3	0	0.00	0	51.3	47.2	2000	0.64	30.2	27	30.3
	52	49	48	50	53												
	51	50	53	53	52										30.4		
	50	53	55	51	48							47.4					
P10 기둥	51	55	51	51	48	51.3	51.3	0	0.00	0	51.3	47.2	2000	0.64	30.2	27	30.3
	48	54	53	50	48												
	49	49	47	54	55										30.4		
	52	50	55	53	52							47.4					
P11 기둥	55	54	51	51	51	50.9	50.9	0	0.00	0	50.9	46.6	2000	0.64	29.9	27	30.0
	48	49	48	50	54												
	53	51	51	55	49										30.2		
	47	48	51	51	50							47.2					
P12 기둥	53	53	48	51	50	50.9	50.9	0	0.00	0	50.9	46.6	2000	0.64	29.9	27	30.0
	53	53	51	50	54												
	51	50	52	55	54										30.2		
	48	49	48	47	48							47.2					
P13 기둥	50	47	51	46	47	48.1	48.1	0	0.00	0	48.1	43.1	2000	0.64	27.6	27	28.2
	46	44	46	48	48												
	46	47	45	50	49										28.9		
	51	49	48	52	51							45.1					
P14 기둥	50	48	48	46	45	48.6	48.6	0	0.00	0	48.6	43.7	2000	0.64	28.0	27	28.5
	46	47	46	46	46												
	48	45	46	50	47										29.1		
	52	54	54	52	55							45.5					
A2 흉벽	48	47	48	50	51	47.7	47.7	0	0.00	0	47.7	42.6	2000	0.64	27.3	24	28.0
	46	45	45	44	47												
	45	43	48	48	49										28.7		
	51	50	51	50	48							44.8					