

위치	측 정 치					평균치	평균치	타격각도	▽R1	▽R3	기준강도	f	재령	α	f ₂₈	Mpa	추정강도
						(R ₁)	(R ₂)	(α)	(ΔR)	(ΔR')	(R ⁰)						
A1 흉벽	45	51	47	50	45	47.4	47.4	0	0.00	0	47.4	42.2	2000	0.64	27.0	24	27.8
	44	45	51	39	50												
	49	51	48	49	45												
	49	49	44	48	48							44.6			28.5		
P1 기둥	55	54	43	47	51	48.0	48.0	0	0.00	0	48.0	43.0	2000	0.64	27.5	27	28.2
	50	43	44	46	48												
	45	45	47	48	49												
	45	48	54	50	48							45.0			28.8		
P2 기둥	53	53	45	44	47	47.9	47.9	0	0.00	0	47.9	42.8	2000	0.64	27.4	27	28.1
	48	46	46	44	45												
	49	47	51	52	51												
	45	44	47	50	50							45.0			28.8		
P3 기둥	52	48	48	49	45	47.2	47.2	0	0.00	0	47.2	41.9	2000	0.64	26.8	27	27.6
	47	48	45	45	44												
	49	47	48	45	44												
	51	49	47	48	44							44.5			28.5		
P4 기둥	45	46	46	48	48	48.3	48.3	0	0.00	0	48.3	43.3	2000	0.64	27.7	27	28.4
	48	49	48	47	47												
	50	50	50	48	49												
	48	49	50	51	48							45.3			29.0		
P5 기둥	49	51	51	46	47	48.2	48.2	0	0.00	0	48.2	43.2	2000	0.64	27.7	27	28.3
	44	45	45	47	50												
	46	47	49	46	50												
	47	51	51	52	49							45.2			28.9		
P6 기둥	52	50	50	49	50	48.8	48.8	0	0.00	0	48.8	44.0	2000	0.64	28.1	27	28.7
	52	50	47	47	48												
	48	48	48	45	44												
	50	51	51	48	48							45.6			29.2		
P7 코핑부배면	49	50	53	51	47	51.4	51.4	0	0.00	0	51.4	47.3	2000	0.64	30.3	27	30.3
	52	56	48	50	49												
	53	55	49	54	48												
	54	51	53	53	52							47.5			30.4		
P8 기둥	50	51	50	48	47	49.0	49.0	0	0.00	0	49.0	44.2	2000	0.64	28.3	27	28.8
	51	48	48	47	45												
	50	50	52	53	50												
	47	47	48	49	48							45.8			29.3		
P9 기둥	46	46	47	46	45	47.4	47.4	0	0.00	0	47.4	42.2	2000	0.64	27.0	27	27.8
	48	46	49	46	46												
	48	49	46	47	49												
	47	48	48	49	51							44.6			28.5		
P10 기둥	48	42	49	50	51	48.7	48.7	0	0.00	0	48.7	43.8	2000	0.64	28.1	27	28.6
	48	47	48	45	48												
	48	50	50	49	49												
	50	52	48	51	50							45.6			29.2		
P11 기둥	48	50	51	50	50	48.5	48.5	0	0.00	0	48.5	43.6	2000	0.64	27.9	27	28.5
	51	50	48	48	51												
	51	52	48	46	47												
	45	48	45	44	46							45.4			29.1		
P12 기둥	50	51	51	50	47	49.1	49.1	0	0.00	0	49.1	44.4	2000	0.64	28.4	27	28.9
	51	49	48	51	50												
	47	51	52	52	50												
	48	48	43	46	47							45.8			29.3		
P13 기둥	48	46	51	48	48	48.0	48.0	0	0.00	0	48.0	43.0	2000	0.64	27.5	27	28.2
	48	48	47	41	43												
	49	50	51	51	51												
	48	46	47	48	50							45.0			28.8		
P14 기둥	50	50	51	50	47	48.5	48.5	0	0.00	0	48.5	43.6	2000	0.64	27.9	27	28.5
	49	48	48	49	50												
	48	50	48	48	45												
	48	48	47	47	48							45.4			29.1		
A2 흉벽	58	49	41	50	30	48.3	48.3	0	0.00	0	48.3	43.3	2000	0.64	27.7	24	28.4
	51	55	50	58	57												
	55	40	39	43	41												
	48	55	50	47	48							45.3			29.0		