

위치	측 정 치					평균치	평균치	타격도	▽R1	▽R3	기준강도	f	재령	α	f ₂₈	Mpa	추정강도
						(R ₁)	(R ₂)	(α)	(ΔR)	(ΔR')	(R ⁰)						
월문1터널(서울) Span2	45	46	45	44	44	45.5	45.5	0	0.00	0	45.5	39.8	2000	0.64	25.5	24	26.6
	44	45	47	46	45												
	45	44	46	48	44												
	48	45	46	45	47							43.2			27.7		
월문1터널(서울) Span36	47	47	47	50	50	48.7	48.7	0	0.00	0	48.7	43.8	2000	0.64	28.1	24	28.6
	46	46	47	46	49												
	48	45	49	48	52												
	51	50	51	52	53							45.6			29.2		
월문1터널(서울) Span53	50	48	54	55	53	51.0	51.0	0	0.00	0	51.0	46.8	2000	0.64	29.9	24	30.1
	54	50	49	50	52												
	48	48	49	49	50												
	53	54	50	51	52							47.2			30.2		
월문1터널(서울) Span78	44	44	49	47	50	46.2	46.2	0	0.00	0	46.2	40.7	2000	0.64	26.0	24	27.0
	46	48	44	48	45												
	46	46	45	47	44												
	44	44	45	48	50							43.7			28.0		
월문1터널(서울) Span137	48	48	51	41	53	49.3	49.3	0	0.00	0	49.3	44.6	2000	0.64	28.6	24	29.0
	50	50	49	50	52												
	48	48	49	49	50												
	48	49	50	51	52							46.0			29.4		