

위치	측 정 치					평균치	평균치	타격각도	▽ R1	▽ R3	기준강도	f	재령	α	f_{28}	Mpa	추정강도
						(R ₁)	(R ₂)	(α)	(ΔR)	($\Delta R'$)	(R ⁰)						
월문1터널(양양) Span 2	47	47	47	48	50	49.0	49.0	0	0.00	0	49.0	44.2	2000	0.64	28.3	24	28.8
	48	48	50	50	48												
	50	50	48	49	48							45.8			29.3		
	52	48	52	48	52												
월문1터널(양양) Span 31	45	45	46	47	46	47.4	47.4	0	0.00	0	47.4	42.2	2000	0.64	27.0	24	27.8
	46	49	53	49	48												
	47	50	50	49	47							44.6			28.5		
	47	46	45	46	47												
월문1터널(양양) Span 67	50	47	50	48	50	49.4	49.4	0	0.00	0	49.4	44.7	2000	0.64	28.6	24	29.1
	48	48	50	50	48												
	50	50	48	49	48							46.1			29.5		
	52	51	51	48	52												
월문1터널(양양) Span 106	49	48	49	47	49	47.8	47.8	0	0.00	0	47.8	42.7	2000	0.64	27.3	24	28.0
	51	48	48	48	49												
	48	46	49	48	48							44.9			28.7		
	46	45	48	46	46												
월문1터널(양양) Span 139	48	49	45	46	46	46.7	46.7	0	0.00	0	46.7	41.3	2000	0.64	26.4	24	27.3
	47	44	48	45	46												
	46	48	49	45	47							44.1			28.2		
	46	48	48	46	46												