

RC-RADAR		도곡2교 철근탐사 자료					
PROJECT TITLE		국도45호선 도곡2교 등 3개소 정밀안전점검 및 내진성능평가용역					
Company		(주)명성엔지니어링		Client		수원국토관리사무소	
시험 결과							
No	위치	철근방향	실측 배근간격 (mm)	설계 배근간격 (mm)	실측 피복두께 (mm)	설계 피복두께 (mm)	비고
1	S1 바닥판하면	주철근	120	100	41	60	양호
		배력철근	172	150	41	60	양호
2	S2 바닥판하면	주철근	120	100	41	60	양호
		배력철근	171	150	44	60	양호
3	S3 바닥판하면	주철근	116	100	41	60	양호
		배력철근	170	150	41	60	양호
4	S4 바닥판하면	주철근	111	100	44	60	양호
		배력철근	171	150	50	60	양호
5	A1 교대	수직철근	123	125	73	50	양호
		수평철근	188	200	82	50	양호
6	A2 교대	수직철근	133	125	72	50	양호
		수평철근	211	200	80	50	양호
7	P1 교각 코핑	수직철근	200	200	112	100	양호
		수평철근	153	150	158	100	양호
8	P2 교각 코핑	수직철근	202	200	105	100	양호
		수평철근	140	150	156	100	양호
9	P3 교각 코핑	수직철근	181	200	112	100	양호
		수평철근	170	150	160	100	양호





