

RC-RADAR		금남IC2교 철근탐사 자료					
PROJECT TITLE		국도46호선 금남IC2교 등 5개소 성능평가용역					
Company		(주)명성엔지니어링		Client		의정부국토관리사무소	
시험 결과							
No	위치	철근방향	실측 배근간격 (mm)	설계 배근간격 (mm)	실측 피복두께 (mm)	설계 피복두께 (mm)	비고
1	S1 바닥판하면	주철근	125	125	54	40	양호
		배력철근	115	125	48	40	양호
2	염화물 S2 바닥판하면	주철근	125	125	55	40	양호
		배력철근	125	125	50	40	양호
3	A1 교대	수직철근	260	250	92	100	양호
		수평철근	160	150	95	100	양호
4	P2 교각	수직철근	160	100	70	100	양호
		수평철근	150	150	83	100	양호
5	염화물 P2 교각	수직철근	140	100	73	100	양호
		수평철근	170	150	84	100	양호





