

RC-RADAR		금남IC R-A교(상) 철근탐사 자료					
PROJECT TITLE		국도46호선 금남IC2교 등 5개소 성능평가용역					
Company		(주)명성엔지니어링		Client		의정부국토관리사무소	
시험 결과							
No	위치	철근방향	실측 배근간격 (mm)	설계 배근간격 (mm)	실측 피복두께 (mm)	설계 피복두께 (mm)	비고
1	S1 바닥판하면	주철근	130	125	37	40	양호
		배력철근	145	150	41	40	양호
2	염화물 S3 바닥판하면	주철근	130	125	44	40	양호
		배력철근	150	150	41	40	양호
3	S1 거터	주철근	170	200	50	40	양호
		배력철근	175	189	51	40	양호
4	A1 교대	수직철근	245	250	102	100	양호
		수평철근	155	150	104	100	양호
5	P2 교각	수직철근	105	100	103	100	양호
		수평철근	280	300	99	100	양호
6	염화물 P2 교각	수직철근	180	200	97	100	양호
		수평철근	230	300	102	100	양호





