

RC-RADAR		동향교 철근탐사 자료					
PROJECT TITLE		2024년 국도38호선 이동교(상) 등 3개소 정밀안전점검 및 2중 성능평가용역					
Company		(주)명성엔지니어링		Client		수원국토관리사무소	
시험 결과							
No	위치	철근방향	실측 배근간격 (mm)	설계 배근간격 (mm)	실측 피복두께 (mm)	설계 피복두께 (mm)	비고
1	S03 바닥판하면	주철근	90	100	41	60	양호
		배력철근	300	300	37	60	양호
2	염화물 S11 바닥판하면	주철근	105	100	44	60	양호
		배력철근	310	300	37	60	양호
3	S11-G3 거더	주철근	185	200	41	60	양호
		배력철근	390	300	41	60	양호
4	S14-G3 거더	주철근	120	200	67	60	양호
		배력철근	210	300	63	60	양호
5	S11 가로보	주철근	200	250	44	50	양호
		배력철근	300	200	54	50	양호
6	염화물 A2 교대 흥벽	수직철근	130	125	55	50	양호
		수평철근	200	200	57	50	양호
7	P11 교각 기둥부	수직철근	120	150	106	100	양호
		수평철근	300	300	76	100	양호
8	P12 교각 기둥부	수직철근	110	150	97	100	양호
		수평철근	155	300	100	100	양호
9	P13 교각 기둥부	수직철근	200	150	98	100	양호
		수평철근	150	300	100	100	양호





