


16. 원평천교 토공노반(G54)



위치	STA. 113K010-020	선별	위치	채움
내용	균열	Cw= 0.5/6.1		



위치	STA. 113K010-020	선별	T2	위치	TCL
내용	균열	Cw= 0.5/1.4			




위치	STA. 113K010-020	선별	T2	위치	TCL
내용	균열	Cw= 0.5/0.7			



위치	STA. 113K030-040	선별	T1	위치	TLC
내용	박리	A= 0.1x0.3			



위치	STA. 113K030-040	선별	T1	위치	TCL
내용	망상균열	A= 3.0x3.0			



위치	STA. 113K200-210	선별	T1	위치	TCL
내용	재로분리	A= 0.1x0.1			




위치	STA. 113K300-310	선별	T1	위치	침목
내용	파손	A= 0.1x0.1			




위치	STA. 113K440-410	선별	T1	위치	TCL
내용	재료분리	A= 0.2x0.6			



위치	STA. 113K540-550	선별	T2	위치	TCL
내용	균열	Cw= 0.5/0.7			




위치	STA. 113K660-670	선별	T1	위치	침목
내용	파손	A= 0.1x0.1			



위치	STA. 113K700-710	선별	T1	위치	TCL
내용	재료분리	A= 0.1x0.1			



위치	STA. 113K810-820	선별	T2	위치	TCL
내용	재료분리	A= 0.3x0.2			



위치	STA. 113K840-850	선별	T2	위치	침목
내용	파손	A= 0.1x0.1			



위치	STA. 113K840-850	선별	T2	위치	침목
내용	파손(2EA)	A= 0.1x0.1			




위치	STA. 113K970-980	선별		위치	채움
내용	균열	Cw= 0.5/1.2			



위치	STA. 113K990-114K000	선별		위치	채움
내용	균열	Cw= 0.5/0.1			




위치	STA. 114K100-110	선별	T2	위치	TCL
내용	박리	A= 0.1x0.5			



위치	STA. 114K120-130	선별	T1	위치	TCL
내용	박락	A= 0.3x0.2			




위치	STA. 1148170-180	선별	T2	위치	HSB
내용	백태	A= 0.2x1.5			




위치	STA. 114K200-210	선별	T1	위치	TCL
내용	표면열화	A= 0.5x0.4			




위치	STA. 114K210-220	선별	T1	위치	TCL
내용	파손	A= 0.2x0.1			



위치	STA. 114K320-330	선별	T1	위치	HSB
내용	박락	A= 0.2x0.2			



위치	STA. 114K220-230	선별	T1	위치	침목
내용	파손	A= 0.1x0.1			



위치	STA. 114K220-230	선별	T1	위치	침목
내용	파손	A= 0.1x0.1			