


호남고속선 갈산터널_302(12.061~12.071km, S302)



행번	손상	폭	연청	비고	행번	손상	폭	연청	비고	행번	손상	폭	연청	비고			
1	균열	0.2	mm	0.60	m	56	균열	0.2	mm	0.40	m	111	균열	0.2	mm	0.10	m
2	균열	0.2	mm	0.40	m	57	균열	0.2	mm	0.40	m	112	균열	0.2	mm	0.30	m
3	장격부 균열	0.3	mm	0.40	m	58	균열	0.2	mm	0.40	m	113	균열	0.2	mm	0.40	m
4	균열	0.2	mm	0.60	m	59	균열	0.2	mm	0.40	m	114	균열	0.2	mm	0.30	m
5	균열	0.2	mm	0.60	m	60	균열	0.2	mm	0.40	m	115	균열	0.2	mm	0.10	m
6	균열	0.2	mm	0.30	m	61	균열	0.2	mm	0.30	m	116	균열	0.2	mm	0.70	m
7	균열	0.2	mm	0.10	m	62	균열	0.2	mm	0.40	m	117	균열	0.2	mm	0.30	m
8	균열	0.2	mm	0.30	m	63	균열	0.2	mm	0.30	m	118	균열	0.2	mm	0.30	m
9	균열	0.2	mm	0.30	m	64	균열	0.2	mm	0.40	m	119	균열	0.2	mm	0.40	m
10	균열	0.2	mm	0.10	m	65	균열	0.2	mm	0.40	m	120	균열	0.1	mm	0.40	m
11	균열	0.1	mm	0.30	m	66	균열	0.2	mm	0.40	m	121	균열	0.2	mm	0.30	m
12	균열	0.2	mm	0.30	m	67	균열	0.2	mm	0.40	m	122	균열	0.2	mm	0.40	m
13	균열	0.2	mm	0.60	m	68	균열	0.2	mm	0.10	m	123	균열	0.2	mm	0.20	m
14	균열	0.2	mm	0.20	m	69	균열	0.2	mm	0.40	m	124	균열	1.0	mm	2.00	m
15	균열	0.1	mm	0.30	m	70	균열	0.2	mm	0.40	m	125	균열	0.2	mm	2.00	m
16	균열	0.1	mm	0.30	m	71	균열	0.2	mm	0.40	m	126	균열	0.1	mm	0.30	m
17	균열	0.1	mm	0.50	m	72	균열	0.2	mm	0.40	m	127	균열	0.1	mm	0.30	m
18	균열	0.1	mm	0.30	m	73	균열	0.2	mm	0.10	m	128	균열	0.1	mm	0.30	m
19	균열	0.2	mm	0.60	m	74	균열	0.2	mm	0.40	m	129	균열	0.1	mm	0.30	m
20	균열	0.2	mm	0.30	m	75	장격부 균열	0.3	mm	0.40	m	130	균열	0.1	mm	0.30	m
21	균열	0.2	mm	0.60	m	76	균열	0.2	mm	0.30	m	131					
22	균열	0.2	mm	0.30	m	77	균열	0.2	mm	0.30	m	132					
23	균열	0.1	mm	0.30	m	78	균열	0.2	mm	0.40	m	133					
24	균열	0.2	mm	0.20	m	79	균열	0.2	mm	0.40	m	134					
25	균열	0.2	mm	0.30	m	80	균열	0.2	mm	0.40	m	135					
26	균열	0.1	mm	0.30	m	81	균열	0.2	mm	0.40	m	136					
27	균열	0.2	mm	0.40	m	82	균열	0.2	mm	0.30	m	137					
28	균열	0.2	mm	0.20	m	83	균열	0.2	mm	0.40	m	138					
29	균열	0.2	mm	0.40	m	84	균열	0.2	mm	0.40	m	139					
30	균열	0.2	mm	0.40	m	85	균열	0.2	mm	0.40	m	140					
31	균열	0.2	mm	0.40	m	86	균열	0.2	mm	0.20	m	141					
32	균열	0.2	mm	0.30	m	87	균열	0.2	mm	0.20	m	142					
33	균열	0.2	mm	0.40	m	88	균열	0.2	mm	0.10	m	143					
34	균열	0.2	mm	0.40	m	89	균열	0.2	mm	0.40	m	144					
35	균열	0.2	mm	0.60	m	90	균열	0.2	mm	0.30	m	145					
36	균열	0.2	mm	0.40	m	91	균열	0.2	mm	0.40	m	146					
37	균열	0.2	mm	0.40	m	92	균열	0.2	mm	0.10	m	147					
38	균열	0.2	mm	0.40	m	93	균열	0.2	mm	0.40	m	148					
39	장격부 균열	0.3	mm	0.40	m	94	균열	0.2	mm	0.10	m	149					
40	균열	0.2	mm	0.40	m	95	균열	0.2	mm	0.20	m	150					
41	방수균열	0.4	m	0.40	m	96	균열	0.2	mm	0.10	m	151					
42	균열	0.2	mm	0.10	m	97	균열	0.2	mm	0.40	m	152					
43	균열	0.2	mm	0.50	m	98	균열	0.2	mm	0.40	m	153					
44	균열	0.2	mm	0.10	m	99	균열	0.2	mm	0.10	m	154					
45	균열	0.2	mm	0.30	m	100	균열	0.2	mm	0.30	m	155					
46	균열	0.2	mm	0.60	m	101	균열	0.2	mm	0.30	m	156					
47	균열	0.2	mm	0.40	m	102	균열	0.2	mm	0.30	m	157					
48	균열	0.2	mm	0.40	m	103	균열	0.2	mm	0.30	m	158					
49	균열	0.2	mm	0.40	m	104	균열	0.2	mm	0.30	m	159					
50	균열	0.2	mm	0.40	m	105	균열	0.2	mm	0.40	m	160					
51	장격부 균열	0.3	mm	0.40	m	106	균열	0.2	mm	0.30	m	161					
52	균열	0.2	mm	0.10	m	107	균열	0.2	mm	0.10	m	162					
53	균열	0.2	mm	0.40	m	108	균열	0.2	mm	0.80	m	163					
54	장격부 균열	0.3	mm	0.40	m	109	균열	0.2	mm	0.10	m	164					
55	균열	0.2	mm	0.30	m	110	균열	0.2	mm	0.30	m	165					