

- | | |
|---|-------------------------|
| 1. 성적서 번호 : CMT2014 - 0048 | 5. 접수일자 : 2014년 12월 17일 |
| 2. 의뢰인 업체명 : 우리기술(주) | 6. 완료일자 : 2015년 01월 05일 |
| 주 소 : 경기도 성남시 중원구 상대원동 190-1 | |
| 성 명 : 공 란 | |
| 3. 성과이용목적 : 보고서작성용 | |
| 4. 시 료 명 : 콘크리트 분말 (2014년 광주시 공공하수처리시설 정밀안전진단 용역) | |

시 험 결 과

연 번	구 분	시험 · 검사종목	단 위	시험 · 검사방법	시험 · 검사결과
1	슬래브1	황산염 함량 (SO_4^{2-})	%	KS I 3206 -'08	0.21
2	슬래브2	황산염 함량 (SO_4^{2-})	%		0.33
3	건전부	황산염 함량 (SO_4^{2-})	%		0.06

담당자 : 김 호 진
Tel : 031-646-0804

ki

기술책임자 : 신 도 철
Tel : 031-646-0801

shim

- ※비 고 : 1. 이 시험성적서는 당초 의뢰자가 제출한 시료 및 시료명으로 시험한 결과로서 전체 제품에 대한 품질을 보증 하지는 않습니다.
2. 이 성적서는 홍보, 선전, 광고 및 소송용으로 사용될 수 없으며, 용도 이외의 사용을 금합니다.
3. 이 성적서의 원본 진위확인을 원하시면은 시험담당자의 열람요청을 통해서 확인해 드립니다.

2015년 01월 06일



한국에스지이에스 건설시험연구원

주 소 : 경기도 평택시 서탄면 금암리 520-1
유의사항 : 책임기술자의 이름이 기재되지 아니한 경우에는 성과에 대한 보증을 할 수 없습니다.
총 1 페이지중 1 페이지



This document is issued by the Company under its General Conditions of Service accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

KQP-2510-001-F07 (04)