

RC-RADAR		검상교(천안) 철근탐사 자료					
PROJECT TITLE		시설물 정밀안전진단 용역 [2구역]					
Company		 (주) 한국구조물안전연구원  (주) 한 맥 기 술	Client		 (주)천안논산고속도로		
시험 결과							
No	위치	철근방향	실측 배근간격 (mm)	설계 배근간격 (mm)	실측 피복두께 (mm)	설계 피복두께 (mm)	비고
1	캔틸레버 S1	주철근	125	150	89	40	양호
		배력철근	233	250	39	40	양호
2	캔틸레버 S2	주철근	148	150	86	40	양호
		배력철근	225	250	42	40	양호
3	캔틸레버 S3	주철근	137	150	86	40	양호
		배력철근	251	250	38	40	양호
4	홍벽 A1	수직철근	150	150	61	50	양호
		수평철근	200	200	48	50	양호5
5	벽체 A2	수직철근	146	150	89	100	양호
		수평철근	225	250	84	100	양호
6	기둥부 P1	수직철근	113	100	86	100	양호
		수평철근	301	300	72	100	양호
7	기둥부 P2	수직철근	91	100	70	100	양호
		수평철근	143	150	70	100	양호





