

RC-RADAR		초봉교(논산) 철근탐사 자료					
PROJECT TITLE		시설물 정밀안전진단 용역 [2구역]					
Company		 (주) 한국구조물안전연구원  (주) 한 맥 기 술	Client		 (주)천안논산고속도로		
시험 결과							
No	위치	철근방향	실측 배근간격 (mm)	설계 배근간격 (mm)	실측 피복두께 (mm)	설계 피복두께 (mm)	비고
1	캔틸레버 S1	주철근	133	150	100	40	양호
		배력철근	258	250	44	40	양호
2	바닥판하면 S2	주철근	300	300	79	40	양호
		배력철근	257	250	41	40	양호
3	캔틸레버 S3	주철근	147	150	79	40	양호
		배력철근	251	250	41	40	양호
4	홍벽 A1	수직철근	128	125	82	50	양호
		수평철근	219	200	79	50	양호
5	홍벽 A2	수직철근	130	125	79	50	양호
		수평철근	205	200	76	50	양호
6	기둥부 P1	수직철근	117	100	86	100	양호
		수평철근	150	150	84	100	양호
7	기둥부 P2	수직철근	103	100	82	100	양호
		수평철근	143	150	73	100	양호





