

RC-RADAR		초봉교(천안) 철근탐사 자료					
PROJECT TITLE		시설물 정밀안전진단 용역 [2구역]					
Company		 (주) 한국구조물안전연구원  (주) 한 맥 기 술		Client		 (주) 천안논산고속도로	
시험 결과							
No	위치	철근방향	실측 배근간격 (mm)	설계 배근간격 (mm)	실측 피복두께 (mm)	설계 피복두께 (mm)	비고
1	캔틸레버 S1	주철근	120	150	82	40	양호
		배력철근	250	250	42	40	양호
2	캔틸레버 S2	주철근	100	150	82	40	양호
		배력철근	226	250	40	40	양호
3	캔틸레버 S3	주철근	117	150	93	40	양호
		배력철근	221	250	42	40	양호
4	홍벽 A1	수직철근	133	125	84	100	양호
		수평철근	186	200	96	100	양호
5	벽체 A2	수직철근	114	125	73	100	양호
		수평철근	209	200	92	100	양호
6	기둥부 P1	수직철근	100	100	86	100	양호
		수평철근	144	150	78	100	양호
7	기둥부 P2	수직철근	101	100	76	100	양호
		수평철근	153	150	73	100	양호





