

RC-RADAR		용성2교(천안) 철근탐사 자료					
PROJECT TITLE		시설물 정밀안전진단 용역 [2구역]					
Company		 (주) 한국구조물안전연구원  (주) 한 맥 기 술		Client		 (주)천안논산고속도로	
시험 결과							
No	위치	철근방향	실측 배근간격 (mm)	설계 배근간격 (mm)	실측 피복두께 (mm)	설계 피복두께 (mm)	비고
1	캔틸레버 S1	주철근	133	120	89	40	양호
		배력철근	250	250	44	40	양호
2	캔틸레버 S2	주철근	113	120	85	40	양호
		배력철근	247	250	44	40	양호
3	캔틸레버 S3	주철근	121	120	86	40	양호
		배력철근	247	250	47	40	양호
4	홍벽 A1	수직철근	125	125	44	50	양호
		수평철근	208	200	37	50	양호
5	홍벽 A2	수직철근	117	125	44	50	양호
		수평철근	203	200	44	50	양호
6	기둥부 P1	수직철근	119	100	97	100	양호
		수평철근	142	150	82	100	양호
7	코핑부 P2	수직철근	192	200	93	100	양호
		수평철근	312	300	86	100	양호





