

RC-RADAR		논산JCT교 철근탐사 자료					
PROJECT TITLE		시설물 정밀안전진단 용역 [2구역]					
Company		 (주) 한국구조물안전연구원  (주) 한 맥 기 술	Client		 (주)천안논산고속도로		
시험 결과							
No	위치	철근방향	실측 배근간격 (mm)	설계 배근간격 (mm)	실측 피복두께 (mm)	설계 피복두께 (mm)	비고
1	캐틸레버 S1	주철근	166	150	84	40	양호
		배력철근	312	300	44	40	양호
2	캐틸레버 S2	주철근	133	125	77	40	양호
		배력철근	275	300	39	40	양호
3	바닥판하면 S3	주철근	148	150	84	40	양호
		배력철근	312	300	41	40	양호
4	벽체 A1	수직철근	160	150	79	100	양호
		수평철근	150	150	64	100	양호
5	벽체 A2	수직철근	307	300	63	100	양호
		수평철근	157	150	67	100	양호
6	기둥부 P1	수직철근	113	100	84	100	양호
		수평철근	150	150	84	100	양호
7	기둥부 P2	수직철근	109	100	74	100	양호
		수평철근	157	150	67	100	양호





